



भारतीय रिज़र्व बैंक
RESERVE BANK OF INDIA
www.rbi.org.in

E-tender no: [RBI/Kochi Regional Office/Estate/5/25-26/ET/191](#)

Name of the Work: Design, Supply, Installation, Testing, and Commissioning of Audio-Conferencing System for Conference Room at Office Building, Reserve Bank of India, Kochi

Addendum

The pre-bid meeting for the captioned work was held at 15:00 hrs. on July 07, 2025, at the Office Building, as per the NIT published in the RBI website and MSTC Portal. The list of Bank's Officials / bidder's representatives who attended the meeting are as tabulated below.

The Bank's Officials	Firm / Prospective Tenderers and their representatives
1. Shri. Rishu V. Singh (AM (Tech.)) 2. Smt. Gopika S. V. (JE (Civil))	1. Shri. Biju Gopal, M/s Systronics India Ltd., Telerad Division, Thiruvananthapuram (mail id. - biyu@teleradindia.com , phone no.- 9567225555). 2. Shri. Shaju George, M/s Voxdata tech. Pvt. Ltd. (mail id. - support@voxdatatech.com , phone no.- 9846435610).

The queries put forth by the representatives and their respective clarifications given by the Bank are as tabulated below.

Sl. No.	Queries / Statements from the firm(s)	Answers / Clarifications from the Bank's side, if any.
1	Clarification required on whether microphones required are of tabletop or table-embedded models (section-VII-para-5 and part-II (item sl. no. 4 and 5) of tender document).	The tenderers may quote for only tabletop model microphones under this tender.
2	Whether cable retraction modules are compulsory in case of cable-cubby unit (section-VII-para-5 and part-II (item sl. no. 6) of tender document).	Yes, the flush-mount cable cubby units shall be equipped with cable retraction modules.
3	Is the Bank's 'Samvadh' VC system to be merged with the new audio-conferencing system (section-VII-para-1.1 of tender document).	The merging / integration of these systems are not required under the scope of this tender. However, the new audio-conferencing system should be compatible for any

		integration with 'Samvadh', or any third-party AV-VC meeting applications.
4	Is the cable cubby unit specified is of flush-type or projecting-type (section-VII-para-5 and part-II (item sl. no. 6) of tender document).	The cable cubby units to be quoted under this tender are flush-type ones with sleek design and metal body and lid.

Note:

- i) This document (the minutes of the pre-bid meeting) shall form a part of the tender.
- ii) The terms and conditions and specifications of the tender document shall continue to remain the same.
- iii) The above amendments / clarifications are issued for the information of all the intending bidders.
- iv) The bidders shall quote prices exclusive of applicable GST, against each item in the bill of quantities.

July 09, 2025

Chief General Manager
Reserve Bank of India, Kochi