



**Corrigendum-2 - Design, Supply, Installation, Testing and Commissioning (DSITC) of Intelligent Addressable Analogue Fire Alarm System for Bank's office premises at Riverfront House in Ahmedabad**

Reserve Bank of India, Ahmedabad has placed e-tender for Design, Supply, Installation, Testing and Commissioning (DSITC) of Intelligent Addressable Analogue Fire Alarm System for Bank's office premises at Riverfront House in Ahmedabad through E-tender No: [RBI/Ahmedabad/Ahmedabad/28/20-21/ET/777](https://www.rbi.org.in/portal/pressnote/202105/2021052801.html) on the RBI Website / MSTC portal on May 31, 2021 and the last date for submission of the e-tender is scheduled on June 15, 2021 up to 15.00 hrs.

2. In this context, it is notified that

(A) minimum capacity of loop card has been revised from "150 addressable detectors & 150 addressable devices" to "a total of 250 addressable devices & detectors". Accordingly, following revisions have been made:

Clause 9.3-B. Main Fire Alarm Control Panel (MFACP) on page no. 82 of the tender stands revised as "*..... Fire Alarm panel shall be a multi-loop (exact number of loops as per schedule of quantity) panel and all the loop card should be of same size with a minimum capacity of **250 addressable detectors & devices**. .....*".

This revision in minimum capacity of loop card (from 150 addressable detectors + 150 addressable devices to total 250 addressable detectors & devices) shall also be applicable to Item 5 of "Section X: Schedule of Technical Information" and Item 1 of "Bill of Quantities".

(B) Item 7 of "Bill of Quantities" pertaining to Hooter cum Strobe light stands corrected as "***Hooter cum Strobe Light (as per Section IX: Technical Specifications) Supply, Installation, Testing and Commissioning of 80 dB Addressable Hooter cum Strobe Light with control light. The sounder should be wall & ceiling mountable and facilitate selection of one tone from minimum 8 available tone variants. (Rate inclusive of GST, as applicable)***"

3. All other conditions of the tender stand unaltered.

4. This corrigendum shall form part of the tender and a duly signed & stamped copy of the same has to be submitted with the tender.

**Regional Director  
for Gujarat, Daman & Diu and Dadra & Nagar Haveli**