



**Corrigendum-Tender for Design, Supply, Installation, Testing and Commissioning of 2X120 KVA Uninterrupted Power Supply System in N+1 Parallel Redundant Mode at Bank's Office Building, Reserve Bank of India, Chandigarh 160017**

**E-tender No.- [RBI/Chandigarh/Estate/175/20-21/ET/245](#)**

Reserve Bank of India, Chandigarh had invited applications from eligible firms/vendors (OEM) for the captioned work through e-tender route on MSTC website (<https://www.mstcecommerce.com/eprochome/rbi/>) on October 29, 2020.

It has been decided to modify serial no. E (Isolation Transformer) of Section X given in the Tender as under:

<b>Serial no. E of Section X</b>	<b>In Tender</b>	<b>Modification/Changes</b>
Isolation Transformer	To be provided on input side externally	Isolation transformer is to be provided at the Input side and can be provided either inbuilt or external to the UPS cabinet.

All the other terms and conditions of the Tender remain unchanged