



भारतीय रिजर्व बैंक / Reserve Bank of India  
सम्पदा विभाग / Estate Department  
चंडीगढ़ / Chandigarh

**Corrigendum-Tender for DSITC of 400 KVA DG Set with Acoustic enclosure and AMF panel at MOB, RBI Chandigarh**

**NIT-RBI/Chandigarh/Estate/356/20-21/ET/524**

Please refer to the tender notice for the captioned tender published on the Bank's website [www.rbi.org.in](http://www.rbi.org.in) on February 15, 2021 inviting applications from eligible firms/vendors for the captioned work through e-tender route on MSTC website (<https://www.mstcecommerce.com/eprochome/rbi/>).

Now, the Bank has decided to modify some of the conditions in the Tender as given below:

1. Please read para "Acoustic enclosure" mentioned at Page No. 51 under Section VII of Tender Document as "Acoustic enclosure shall be powder coated and fabricated out of minimum 1.6 mm thickness MS sheet instead of 1.4 mm thickness MS sheet".
2. The length of MS exhaust pipe with insulation in BOQ may be considered as 8 metre and diameter shall be as per manufacturer standard. The civil foundation of the DG Set shall be provided by the Bank. The size shall be indicated by the successful bidder.